WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 3474
Permit No. 105
Basin ~~105~~ 103 - DAYTON V

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15189

1. OWNER Richard Seamen
MAILING ADDRESS 2734 NYE dr, Minden NV 89423

ADDRESS AT WELL LOCATION 1644 Johnson Ln

2. LOCATION NE ¼ SE ¼ Sec. 2 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. 23490-11 (Issued by Water Resources) Parcel No. Johnson Lane (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	15	
SAND & Rock		15	25	
SAND		25	35	
SAND & Rock		35	50	
SAND		50	75	
SAND Gravel & Rock		25	80	
SAND		80	110	
CLAY SAND & Gravel		110	120	
CLAY & SAND		120	160	
SAND	X	160	180	
SAND & Gravel	X	180	200	
SAND	X	200	210	

'90 OCT 18 P3:43
STATE ENGINEER

Date started 9-19, 19 90
Date completed 9-21, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air	20+	–	2½ hrs

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 210 feet
..... inches
..... inches
Casing record ASTM 10XX
Weight per foot ..... Thickness .156

Diameter	From	To
6 inches	0 feet	210 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 210 feet to 50 feet

Perforations:
Type perforation Factory Perf
Size perforation 3" x 5/32"
From 210 feet to 190 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 158 feet below land surface
Flow 20+ G.P.M. ..... P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Rauchack Drilling Inc (Contractor)
Address 2668 Fuller Minden NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board #021268
Nevada contractor's driller's number issued by the Division of Water Resources #1380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1495
Signed Michael Allen
By driller performing actual drilling on site or contractor
Date 9-24-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627