WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34719
Permit No.
Basin 9-100

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13507

1. OWNER Ray Graham
MAILING ADDRESS 560 PETE HENDRICKS RD. YERINGTON, NV. 89447
ADDRESS AT WELL LOCATION 560 PETE HENDRICKS RD YERINGTON, NV. 89447

2. LOCATION SE ¼ SE ¼ Sec. 34 T. 14 N/S R. 26 E. Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. 14-381-12 Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil-Sandy		0	5	5
Coarse Sand, Gravel				
Rock Fill		5	35	30
Coarse Sand, Gravel				
Rock Fill with				
Clay		35	70	35
Clay, Coarse Sand				
Gravel		70	87	17
Coarse Sand, Gravel	X			
Clay		87	105	18
Coarse Sand +				
Gravel	X	105	130	25
Clay, Coarse Sand				
Gravel		130	135	5
Coarse Sand +				
Gravel	X	135	145	10
Coarse Sand +				
Gravel with Clay				
Stratas	X	145	149'6"	4'6"

Date started 9-25-90, 1990
Date completed 9-28, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 22 Draw down 10 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 11¼ inches Total depth 150'6" feet
inches
inches
Casing record
Weight per foot Thickness .156

Diameter	From	To
6⅝ inches	+1 feet	149'6" feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement Grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 149'6" feet

Perforations:
Type perforation Sawed
Size perforation 3/32" x 3"
From 129'6" feet to 149'6" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 87 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Lane Yerington (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada contractor's driller's number issued by the Division of Water Resources 634
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Larry Ogden (By driller performing actual drilling on site or contractor)
Date 9-28-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627