


OFFICE USE ONLY
 Log No. 34721
 Permit No. _____
 Basin 8-02



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT 0-1-83

PRINT OR TYPE ONLY

1. OWNER Margaret Robinson ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2 Canyon Drive 2 Canyon Drive
Carson City, NV 89703 Carson City, NV 89703
 2. LOCATION SW 1/4 SW 1/4 Sec. 13 T. 15 Q/S R. 19 E. Carson City County _____
 PERMIT NO. 07-133-02 Kings Canyon Park #1 Subdivision Name _____
Issued by Water Resources Parcel No.

3. TYPE OF WORK
 New Well Recondition
 Deepen Abandonment

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned existing 8 inch domestic well.				
Well depth is unknown as we were unable to locate any well log for this well.				
Abandonment process was witnessed by two (2) representatives from the State Engineers' office.				
Ran perforator, (air activated), in well on drill pipe and perforated from the top down to 46 feet. Unable to get perforator to a greater depth due to collapsed casing.				
Placed grout pipe in well and pumped a neat cement mixture with our grout plant, filling casing from the bottom up, displacing the water and with the grout mixture penetrating into the formation and behind the casing through the perforations.				
Placed 40 sacks of cement during this procedure.				

8. WELL CONSTRUCTION

Diameter 8 inches Total depth Unknown feet

Casing record 8" .138

Weight per foot _____ Thickness _____

Diameter	From	To
<u>8</u> inches	<u>2</u> feet	<u>Unknown</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement

Depth of seal Unknown feet

Gravel packed: Yes No

Gravel packed from _____ feet to _____ feet

Perforations:

Type perforation Unknown

Size perforation Unknown

From Unknown feet to _____ feet

From _____ feet to _____ feet

Date started Oct 25, 1990
 Date completed Oct 26, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 37 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO. Contractor

Address CARSON CITY, NV 89701 Contractor

Nevada contractor's license number issued by the State Contractor's Board 23295

Nevada contractor's driller's number issued by the Division of Water Resources _____

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674

Signed [Signature] By driller performing actual drilling on site or contractor

Date 10/26/90