WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 3422
Permit No.
Basin 8-104

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1446

1. OWNER Margaret Robinson
MAILING ADDRESS 2 Canyon Drive
Carson City, NV 89703

ADDRESS AT WELL LOCATION 2 Canyon Drive
Carson City, NV 89703

2. LOCATION SW ¼ SW ¼ Sec. 13 T. 15 0 S R. 19 E Carson City County
PERMIT NO. (Issued by Water Resources) 07-133-02 (Parcel No.) Kings Canyon Park #1 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒ Mud
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden - Boulders with loose soil		0	11	11
Talus rock, broken, hard to very hard with clay		11	81	70
Highly fractured granite with clay seams		81	151	70
Clay seams, tight to very tight, slate grey coloring		151	155	4
Fractured granite with 2-3 gpm water	x	155	158	3
Clay seam, seam very tight		158	167	9
Fractured granite with water	x	167	190	23
T.D. 190				

Date started Oct 18, 19 90
Date completed Oct 24, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed mud from well with clean water and gravel packed well. Developed well with air and blew 18 to 20 gpm from 160 feet			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. 100' WELL CONSTRUCTION
Diameter 11 ¼ inches Total depth 190 feet
9 3/4 inches
inches
Casing record 6 5/8" Steel
Weight per foot 13.03 Thickness .188

Diameter	From	To
6 5/8 inches	2 feet	190 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 100 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 100 feet to 190 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3" x 3/32"
From 170 feet to 190 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 56 feet below land surface
Flow 18 -20 G.P.M. ..... P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10/26/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627