WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34737
Permit No.
Basin 8-102

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10682

1. OWNER Ed Whiting
MAILING ADDRESS P.O. Box 254
Silver Springs Nev. 89429

ADDRESS AT WELL LOCATION
3220 E. 8th Street
Silver Springs Nev 89429

2. LOCATION SW ¼ SW ¼ Sec. 16 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) 17-371-05 (Parcel No.) Stockton Sub # 2 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SAND | | 0' | 4' | 4' |
| Silt + SAND | | 4' | 50' | 46' |
| CLAY | | 50 | 55' | 5' |
| COARSE SAND | ✓ | 55' | 65' | 10' |
| CLAY + SAND | | 65 | 75' | 10' |
| GRAY CLAY | | 75 | 80' | 5' |
| GRAY SAND | | 80' | 100' | 20' |
| BROWN CLAY | | 100 | 105' | 5' |
| BROWN SAND (FINE) | | 105' | 120' | 15' |
| BROWN CLAY | | 120 | 125 | 5' |
| GRAY SAND | | 125 | 127' | 2' |
| BROWN CLAY | | 127' | 130' | 3' |
| BROWN + GRAY SAND (COARSE) | ✓ | 130 | 140 | 10' |

OCT 30 '90 A9:55 RECEIVED STATE ENGINEERS OFFICE

Date started Oct, 19 90
Date completed Oct 27, 19 90

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 10 Draw down 0 feet 4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 140 feet
inches
inches
Casing record
Weight per foot Thickness 188

| Diameter | From | To |
|---|---|---|
| 12 inches | 0 feet | 50 feet |
| 6 inches | 0 feet | 140 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Torch Cut
Size perforation
From 130 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 50 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name VERNON CANNON (Contractor)
Address BOX 214 Silver Springs Nev. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23317
Nevada contractor's driller's number issued by the Division of Water Resources 1455
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1455
Signed Vernon Cannon (By driller performing actual drilling on site or contractor)
Date Oct 28, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627