WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34739
Permit No.
Basin 104-79

cda

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11749

1. OWNER LAWRENCE J. ZEMAN
MAILING ADDRESS HC 32 Box 3052
Ely NV 89301

ADDRESS AT WELL LOCATION Lot 153A
Crosstimbers Subdivision

2. LOCATION ~~NE~~ SE ¼ SW ¼ Sec. 22 T. 17 N/S R. 63 E White Pine County

PERMIT NO. (Issued by Water Resources) | 153 A (Parcel No.) | Crosstimbers Land Co. Sub. (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy top soil		0	3	
Sand & gravel		3	22	19
Sandy Clay		22	30	8
gravel		30	31	1
Sandy Clay		31	38	7
gravel		38	40	2
Clay		40	42	2
gravel-clay con.		42	48	6
clay		48	58	10
gravel Conglomerate	water	58	63	5
Sandy Clay		63	70	7
gravel - cobbles	water	70	73	3
Sandy Clay		73	86	13
gravel con		86	87	1
Sandy clay		87	93	6
gravel	water	93	95	2
Sandy Clay		95	105	10
gravel con.		105	107	2
Lime clay	water	107	117	10
gravel	water	117	119	2
Sandy Clay		119	151	32
gravel	water	151	153	2
Clay		153	155	2
gravel		155	157	2
Sandy clay		157	160	3

Date started Sept 8, 1990
Date completed Sept 25, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 40 Draw down 10 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 160 feet
8 inches
inches
Casing record 161' - 6 5/8"
Weight per foot 12.7 Thickness .188

Diameter	From	To
6 5/8 inches	0 feet	161 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete grout
Depth of seal 5'-50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 160 feet

Perforations:
Type perforation mill
Size perforation 1/8 x 3 x 6 row
From 94 feet to 114 feet
From 134 feet to 154 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard (Contractor)
Address Po Box 176 Lund NV 89317 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada contractor's driller's number issued by the Division of Water Resources 1538
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Darren Maynard (By driller performing actual drilling on site or contractor)
Date Oct 10 - 90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627