

OFFICE USE ONLY
 Log No. 34740
 Permit No. _____
 Basin. 6-87

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14655

1. OWNER Richard & Teri Seher ADDRESS AT WELL LOCATION 490 Mil Drae
 MAILING ADDRESS 3405 Lunsford Ct Lot 3
Reno, Nv 89511

2. LOCATION NW 1/4 NE 1/4 Sec 1 T 18 N/S R. 19 E Washoe County
 PERMIT NO. 040-582-04 Subdivision Name _____
Issued by Water Resources Parcel No.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel clay		0	3	3
Gravel sands red clay		3	6	3
Red brown clay some sand		24	74	50
Coarse gravel small brown clay zones		74	92	18
Sticky brown clay		92	116	24
Brown yellow orange sands & gravels		116	121	5
Sticky clay		121	137	16
Sands & gravels		137	163	26
Brown clay with small gravel layers		163	209	46
Gravels & sands		209	237	28
Sticky brown clay		237	250	13
T.D. 250 ft				

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 250 feet
 _____ inches
 _____ inches

Casing record 6 5/8 inch
 Weight per foot 12.92 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 1 1/2</u> feet	<u>250</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type neat cement
 Depth of seal 100 feet
 Gravel packed: Yes No
 Gravel packed from 100 feet to 250 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 220 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 10/15/90, 19____
 Date completed 10/17/90, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew with air</u>	<u>clear</u>	<u>and develop.</u>	

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 20 feet below land surface
 Flow 20 G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
Contractor
 Address 625 Spice Islands Dr Suite L Sparks
Contractor 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board.
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources.
 Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller
 Signed Roger M Thrall
By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 10/19/90