WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 34744
Permit No.
Basin 6-83

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER K. Ossood
MAILING ADDRESS 790 Buckeye Rd
Reno, NV 89511

ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SW ¼ Sec. 31 T. 18N N/S R. ~~20~~ 21 E. Storey County
PERMIT NO. (Issued by Water Resources) 03-451-36 (Parcel No.) Virginia City Highlands lot 79 (Subdivision Name)

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☑ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐ Air

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Grey Clay with | | | | |
| small boulders | x | 1002 | 1060 | 58 |
| Fractured Dark | | | | |
| Basalt | x | 1060 | 1066 | 6 |
| Grey Clay with | | | | |
| basalt chips | x | 1066 | 1140 | 74 |

90 OCT 26 A9:59
STATE ENGINEER'S OFFICE

Date started Oct 9, 1990
Date completed Oct 15, 1990

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| Air blow @ 6 GPM from | | | |
| 1100 feet | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 1/8 inches Total depth 1120 feet
Casing record 5" From 840 - 1120
Weight per foot 9 Thickness .188

| Diameter | From | To |
|---|---|---|
| 5 inches | 840 feet | 1120 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Machine Slot
Size perforation
From 920 feet to 960 feet
From 980 feet to 1000 feet
From 1040 feet to 1100 feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 945 feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Corp (Contractor)
Address Box 888 (Contractor)
Nevada contractor's license number 11752
Nevada contractor's drillers number 772
Nevada driller's license number 772 (Actual Driller)
Signed [illegible] (Contractor)
Date Oct 17 - 90

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434