

Log # 34757

10-19-'90

# **MPG** MacKAY PUMP & GEOHERMAL, Inc.

DOMESTIC & GEOTHERMAL WATER PUMPS & SYSTEMS  
GEOHERMAL ENGINEERING • PLUMBING & HEATING

NEV. CONT. LIC. #23095, 23096

State Engineer  
Capitol Complex  
201 S. Fall St.  
Carson City, NV 89710

Tom Gallagher, P.E.

Dear Tom:

On this date we have abandoned the well located on the NW corner of Rock and McCarran Blvd. at 4645 Pembroke Lane, Reno, Nevada. The well drillers report is enclosed.

The total depth was approximately 52' and static water level approximately 6'4" below surface.

According to State regulations, we tried to pull the casing out of the hole without success, and then, with the permission of the engineer on site, Rob Martinez, we cut the well casing off about 4' from surface, and filled the well by tremie tube and pressure grouting with neat cement from the bottom to the surface. We were unable to rip the casing with a casing perforator due to the existing power lines directly over the well.

The job was completed on 10-19-'90.

Sincerely,

*R. Bruce MacKay*  
R. Bruce MacKay

**R. BRUCE MacKAY**  
1600 MT. ROSE HIGHWAY  
RENO, NEVADA 89511  
(702) 851-1600

