

OFFICE USE ONLY  
 Log No. 34758  
 Permit No. \_\_\_\_\_  
 Basin 6-87

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11055

1. OWNER WASHOE Co. SCHOOL DIST. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 425 E 9th ST. 2115 ALPHABET DRIVE  
RENO NEV. 89520 RENO, NEV.  
 2. LOCATION SE 1/4 NE 1/4 Sec. 22 T. 19 N. R. 20 E WASHOE County  
 PERMIT NO. M/O 292 051-010-21 DIVISION OF LAND MAP #35  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  M/O

5. TYPE WELL  
 Cable  Rotary   
 Other  AUGER 8"

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN CLAYEY SAND & GRAVEL FILL		0	8	8
BROWN CLAYEY SAND		8	13	5
BROWN SANDY CLAY WITH SOME GRAVEL		13	20	7
BROWN CLAYEY SAND & SILTY CLAY		20	33	13
BROWN STRATIFIED SILTY FINE SAND, CLAYEY SILT & SILTY CLAY - WATER BEDS		33	50	17
NOTE: BENTONITE PELLET SEAL 23' - 26' FEET IN ADDITION TO CEMENT SEAL FROM 0' - 23' FEET.				

8. WELL CONSTRUCTION

Diameter 8 inches Total depth 50 feet

Casing record 0' - 50' FE.

Weight per foot \_\_\_\_\_ Thickness SCH. 40 PVC

Diameter	From	To
<u>2" ID</u> inches	<u>0</u> feet	<u>50</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type CEMENT GROUT

Depth of seal 26 FE. feet

Gravel packed: Yes  No  #3 SAND

Gravel packed from 26 feet to 50 feet

Perforations:  
 Type perforation FACTORY SLOT  
 Size perforation 0.040 WIDE  
 From 25 feet to 45 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started OCT 10, 1990  
 Date completed OCT 12, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>NA</u>	<u>NA</u>	<u>NA</u>	<u>NA</u>
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M. NA Draw down NA feet NA hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 33 feet below land surface  
 Flow NA G.P.M. NA P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EARTH SCIENCE CONSULTANTS Contractor  
 Address 1242 GLENDALE, SPARKS Contractor  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1621  
 Signed Tom Cordova  
 By driller performing actual drilling on site or contractor  
 Date 10/16/90