WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34772
Permit No.
Basin 7-02a

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14646

1. OWNER Ernie Lane
MAILING ADDRESS 1613 Freeport Blvd
Sparks, Nv 89431

ADDRESS AT WELL LOCATION 11065 Wagon Ho Court

2. LOCATION SE ¼ SW ¼ Sec. 25 T. ~~20~~ 21 N S R. 18 E. Washoe County
PERMIT NO. — (Issued by Water Resources) 86-340-25 (Parcel No.) Silver Knolls (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary XX
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sticky brown clay with traces of sand		0	15	15
Sticky green clay		15	75	60
Tan yellow white green coarse sands & gravels & green clay		75	83	8
Sticky green clay		83	91	8
Green yellow white D.G. with clay zones		91	132	41
Dark green clay		132	139	7
T.D. 139 feet				

Date started 9/26/90, 19
Date completed 9/27/90, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 139 feet
inches
inches
Casing record 6 5/8 inch
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	+ 1 feet	139 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type neat cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 139 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 119 feet to 139 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 25 feet below land surface
Flow 20+ G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L Sparks 89431 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada contractor's driller's number issued by the Division of Water Resources 1132
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
Signed Roger M. Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 9/28/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627