

OFFICE USE ONLY
 Log No. 34777
 Permit No. 52524 52528
 Basin. 6-85

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 15584

PRINT OR TYPE ONLY

1. OWNER Springwood/ Bighorn Development ADDRESS AT WELL LOCATION Pyramid Hwy
 MAILING ADDRESS 901 N Stewart St
Carson City, Nv 89701

2. LOCATION SE 1/4 SW 1/4 Sec. 3 T. 20 N/S R. 20 E Washoe County
 PERMIT NO. 52524/52588 89-150-72 Spanish Springs
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D. G. Brown		0	17	17
Multi-colored sands w/traces brown & tan clay		17	75	58
Multi-colored sand w/ fine brown sand trace brown & tan clay		75	112	37
Multi-colored course sands w/trace red clay & fine sand		112	116	4
Brown clay w/some multi-colored sands		116	129	13
Course multi-colored sands some brown clay		129	170	41
Multi-colored sands w/some brown sticky clay		170	175	5
Multi-colored course sands w/ streaks brown clay		175	200	25
T. D. 200 feet				

8. WELL CONSTRUCTION

Diameter 15 inches Total depth 200 feet

Casing record 8 5/8 inch
 Weight per foot 16.94 Thickness .188

Diameter	From	To
<u>8 5/8</u> inches	<u>+1</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type neat cement
 Depth of seal 52 feet
 Gravel packed: Yes No
 Gravel packed from 52 feet to 200 feet

Perforations:
 Type perforation screen [Roscoe Moss]
 Size perforation .100
 From 120 feet to 190 feet
 From _____ feet to _____ feet

Date started 8/29/90, 19____
 Date completed 9/5/90, 19____

7. WELL TEST DATA

Pump RPM	P.M.	Draw Down	After Hours Pump
<u>20</u>	<u>air to clean and develop.</u>		
<u>300</u>	<u>Test pumped at 300 GPM for 72 hrs.</u>		
<u>90</u>			

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 51 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Contractor 625 Spice Islands Dr Suite L Sparks 89431
 Address _____ Contractor _____
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1509
 Division of Water Resources, the on-site driller
 Signed Roger M Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 9/21/90