WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 34798
Permit No. 21813
Basin 10-153
I pg1

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6011

1. OWNER CHARLES E COOPER.
MAILING ADDRESS BOX 117
CANYON TEXAS

ADDRESS AT WELL LOCATION DIAMOND VALLEY
N39 [illegible] W115 [illegible]

2. LOCATION SW ¼ SW ¼ Sec. 15 T. 21 N R. 53 E EUREKA County
PERMIT NO. 19001 (Issued by Water Resources) Parcel No. Replaces Log # 7419 Subdivision Name

3. TYPE OF WORK Replacement
New Well ☒ Recondition ☐ Deepen ☐ Other ☐

PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ REVERSE

6. S.G = sand and gravel

LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	2	2
S.G.		2	24	22
CLAY		24	41	17
S.G.		41	63	22
CLAY		63	68	5
S.G.		68	80	12
CLAY		80	91	11
S.G	57	91	148	57
CLAY		148	152	4
S.G.	14	152	166	14
CLAY		166	176	10
S.G.	4	176	180	4
CLAY		180	192	12
S.G.	3	192	195	3
CLAY		195	206	11
S.G.	17	206	223	17
CLAY		223	239	16
S.G.	8	239	247	8
CLAY		247	257	10
S.G.	6	257	263	6
CLAY		263	272	9
S.G.	15	272	297	15
CLAY		297	301	4
S.G. SOME CLAY STRIPS	26	301	327	26
CLAY		327	334	7
S.G.		334	339	5
CLAY		339	343	4
S.G.		343	366	23

Date started 2-24-90, 19
Date completed 3-[illegible]-90, 19

RECEIVED STATE ENGINEERS OFFICE 90 OCT 29 P3:58

RECEIVED STATE ENGINEERS OFFICE 90 APR 26 P3:47

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	NO TEST		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 27 inches Total depth 373 feet
Casing record 16" and 12" Rosco Moss
Weight per foot ..... Thickness 1/4

Diameter	From	To
16" inches	TOP feet	264 feet
12" inches	264 feet	373 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type .....
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from TOP feet to 373 feet
WELL HAS 30" SURFACE PIPE 50'
Perforations: IN 39" hole.
Type perforation EXTRUDED Rosco Moss
Size perforation 1/8"
From 144 feet to 168 feet
From 192 feet to 264 feet
From 276 feet to 373 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 94.0 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Walter L Plaskett (Contractor)
Address BOX 10 Eureka Nevada (Contractor)
Nevada contractor's license number 11882
Nevada contractor's drillers number .....
Nevada driller's license number James E. Groth (Actual Driller)
Signed 635 (Contractor)
Date 4-10-90

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434

LOG 34798
P92

10-7-90

Division of water Resources
Sirs.

On these two wells we were not aware of Regulations in Regards to plugging of old well. The owners were not aware we don't own the proper Equipment to do the pluging as Required in NRS 534-420.

It seems there should be a more economical method. this could Run into several thousands dollars for each well. most peopl could not afford to Redrill any well with the added cost of pluging old one to your Requirements.

please allow sufficent time to aquire proper Equipment and maybe a less costly method to do the work. (90 to 120 days)

I have notified owners of their obligation to plug these wells.

thank you
James E. Gall
Box 265
Eureka, nevada 89316
lic no. 635