WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34800
Permit No. ~~003918~~
Basin 7-94A

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11134

1. OWNER Deborah McKee
MAILING ADDRESS 15020 Red Rock Rd. RENO NV
ADDRESS AT WELL LOCATION 15020 Red Rock Rd RENO NV

2. LOCATION SE ¼ NW ¼ Sec. 19 T. 22 N/S R. 19 E/ Washoe County
PERMIT NO. ~~003918~~ Issued by Water Resources | 079-371-05 Parcel No. | Red Rock Estates # 75 Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Sands - Top soil. (sealed slots	25'	0	25	1'
Decomposed Mika, Granit & some clays	90'	25'		1½'
	165'		165'	10"+
Some Mika, Granit	190	165'		1½'+
Mud Rock Clay with	235			6"
Some quarts in Fractured Granit	260		288	6"
(Notes)				
HARD Clays of Dark Grays & Greens. in thickness of 20' to 60'.				
Some Fractures in the Mika & Granit around the Aquifer				
Good fast Air Drilling, Did Inject Water & foam.				
Hole substained over a 24 hour piroid. with minimal fill				

Date started 8/20/90, 19
Date completed 8/24/90, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Tested with air-lift			
11 g.p.M.			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6" inches Total depth 288 feet
inches
inches
Casing record ~~188~~ 6 5/8"
Weight per foot 12½ Thickness 188

Diameter	From	To
6 5/8 inches	+ 2 feet	288 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement.
Depth of seal 50 ft feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Torch
Size perforation 6" x 1/8"
From ~~288~~ feet to ~~168~~ feet
From 160 feet to 285 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 90 feet below land surface
Flow ~~11~~ G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ~~Alwest Drilling Inc~~ W. M. Blain Well Drilling
Contractor
Address ~~P.O. Box 1255~~ Wanda Blain Carson City NV
Contractor
625 Airview Suite 107 CC
Nevada contractor's license number issued by the State Contractor's Board 10950
Nevada contractor's driller's number issued by the Division of Water Resources ~~1195~~ 1118
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ~~1118~~ 1195
Signed Charlie Epsha
By driller performing actual drilling on site or contractor
Date Sept 3 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627