WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34805
Permit No. 22352
Basin 10-153

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6006

1. OWNER FRANCIS E NOTAL
MAILING ADDRESS EUREKA, NEVADA 89316
ADDRESS AT WELL LOCATION SAME

2. LOCATION SW ¼ SE ¼ Sec. 19 T. 22 N/S R. 54 E EUREKA County
PERMIT NO. 22352 Issued by Water Resources | Parcel No. | Replace log # 5552 Subdivision Name

3. TYPE OF WORK Redrill
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐ REVERS

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	2	2
SAND		2	44	42
BLACK CLAY		42	67	25
GRAY CLAY		67	90	23
BLACK CLAY		90	97	7
BLACK Sand Blend		97	103	6
CLAY		103	133	30
BLACK CLAY & SAND		133	142	9
Sand GRAVEL	4	142	146	4
BLACK SAND CLAY		146	159	13
SAND GRAVEL	4	159	163	4
CLAY		163	164	1
SAND GRAVEL		164	188	24
CLAY & FINE SAND		188	232	44
SAND GRAVEL	4	232	236	4
CLAY		236	239	3
SAND GRAVEL	3	239	242	3
CLAY		242	244	2
SAND GRAVEL	14	244	258	14

RECEIVED OCT 29 P 3:00 STATE ENGINEERS OFFICE

Date started 7-6-90, 19
Date completed 9-3-90, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
NO PUMP INSTALLED			
NO TEST			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 27 inches Total depth 260 feet
Casing record 16" ROSCO MOSS
Weight per foot ..... Thickness 1/4"

Diameter	From	To
16" inches	0 feet	258 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 258 feet

Perforations:
Type perforation 1/8" ROSCO MOSS
Size perforation
From 161 feet to 185 feet
From 234 feet to 258 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 62 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature COLD F. Quality NOT PUMPED

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PLASKETT IRRIGATION (Contractor)
Address BOX 10 EUREKA, NEV. (Contractor)
Nevada contractor's license number 11882
Nevada contractor's drillers number
Nevada driller's license number 635 (Actual Driller)
Signed James E. Notal (Contractor)
Date 9-27-90

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434

Dear SIRS Rt no. 22352

THE old well is presently being used as a Domestic. Owner does want to Re do the well and keep as a Domestic. IRrigation pump is still installed in old well. please advise as to Requirements. to Re do old well to use as Domestic and proper procedure to plug top.

Thank you
James E Heath
licence # 635
Box 285
Eureka nevada
89316.

as of this date I have notified owner of Record as to the Regulations and Requirements and I am in process of sending a certified notice

Pierre Cardin