

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15507

1. OWNER John Corwin ADDRESS AT WELL LOCATION 1496 Shryock  
 MAILING ADDRESS 1496 Shryock Garderville, NV  
 2. LOCATION NW 1/4 NW 1/4 Sec. 18 T. 10 N/S R. 22 E. Douglas County  
 PERMIT NO. 37-121-39 Parcel No. Shryock Sub. Div. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top Soil</u>	<u>No</u>	<u>1</u>	<u>3</u>	<u>3</u>
<u>Mixed Shale Clay</u>	<u>No</u>	<u>3</u>	<u>100</u>	<u>97</u>
<u>Broken Shale</u>	<u>yes</u>	<u>100</u>	<u>120</u>	<u>20</u>
<u>Green Clay</u>	<u>No</u>	<u>120</u>	<u>140</u>	<u>20</u>
<u>Broken Shale</u>	<u>YES</u>	<u>140</u>	<u>160</u>	<u>20</u>
<u>Brown Clay</u>	<u>No</u>	<u>160</u>	<u>180</u>	<u>20</u>
<u>Broken Shale</u>	<u>yes</u>	<u>180</u>	<u>200</u>	<u>20</u>
<u>Brown Clay</u>	<u>No</u>	<u>200</u>	<u>240</u>	<u>40</u>
<u>Broken Shale</u>	<u>yes</u>	<u>240</u>	<u>280</u>	<u>40</u>
<u>Hard Shale</u>	<u>No</u>	<u>280</u>	<u>300</u>	<u>20</u>
<u>Broken Shale</u>	<u>yes</u>	<u>300</u>	<u>340</u>	<u>40</u>

90 NOV -6 AM 02  
STATE CONTRACTOR

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 280 feet  
6 inches 60'  
         inches

Casing record 6  
 Weight per foot 16 Thickness 1.88

Diameter	From	To
<u>6"</u> inches	<u>71</u> feet	<u>280</u> feet
<u>5"</u> inches	<u>280</u> feet	<u>340</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 280 feet

Perforations:  
 Type perforation Feet 017  
 Size perforation 5/32  
 From 100 feet to 120 feet  
 From 140 feet to 160 feet  
 From 180 feet to 200 feet  
 From 240 feet to 280 feet  
 From 280 feet to 340 feet

Date started Oct 26, 1990  
 Date completed Oct 30, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>10</u>	<u>By Air Lift</u>	
		<u>2 Hr</u>	

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL

Static water level 70 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 62.0 °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EMDKO INC. Contractor  
 Address P.O. Box 82, Smith, NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 24149  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718-T-1  
 Signed James O. Corwin  
 By driller performing actual drilling on site or contractor  
 Date Oct 30 1990