

OFFICE USE ONLY  
 Log No. 34859  
 Permit No. \_\_\_\_\_  
 Basin 9-107

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10817

1. OWNER Herman Rose ADDRESS AT WELL LOCATION Herman Rose Ranch, Wellington Nev.  
 MAILING ADDRESS 89444 Wellington Nev. 89 (19) 5/5/08 Assoc. of Perm. # 2558  
 2. LOCATION S.W. 1/4 NE 1/4 Sec. 46 T. 10 N/S R. 24 E. Lyon County  
 PERMIT NO. None Issued by Water Resources 539-24 Parcel No. 10-9-11-04 Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>aluminum rock + dirt</u>		<u>0</u>	<u>135</u>	<u>135</u>
<u>Rock + gravel</u>		<u>135</u>	<u>156</u>	<u>26</u>
<u>Rock + small brown clay strata</u>		<u>156</u>	<u>200</u>	<u>44</u>
<u>sharp gravel</u>	<u>yes</u>	<u>200</u>	<u>228</u>	<u>28</u>
<u>Rock + small clay strata</u>		<u>228</u>	<u>256</u>	<u>28</u>
<u>rock + gravel</u>	<u>yes</u>	<u>256</u>	<u>300</u>	<u>44</u>

90 SEP 24 AM 108 RECEIVED STATE ENGINEERS OFFICE  
 90 NOV 19 RECEIVED STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Diameter 8 inches Total depth 300 feet  
 Casing record 8 in 0 - 300  
 Weight per foot \_\_\_\_\_ Thickness 188  

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>300</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement grout  
 Depth of seal 50 ft feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation factory saw slot  
 Size perforation 3/32 x 2  
 From 220 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started Aug 16 1990  
 Date completed Aug 30 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 20 Draw down 10 feet 3 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 200 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name F.M.D.L.C.O. Inc. Contractor  
 Address Box 92 Smith Nev. Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 24149  
 Nevada contractor's driller's number issued by the Division of Water Resources 718  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718  
 Signed Edmund Phillips  
 By driller performing actual drilling on site or contractor  
 Date Sept 4 1990