

OFFICE USE ONLY
Log No. 34863
Permit No. _____
Basin B-105
11470

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11470

1. OWNER Justine Blekahorn ADDRESS AT WELL LOCATION _____
MAILING ADDRESS P.O. Box 2877 Leviathan Mine Road
Gardnerville, NV 89410 Gardnerville, NV 89410
2. LOCATION SE 1/4 NE 1/4 Sec 22 T 11 R 21 E Douglas County
PERMIT NO. 35-240-04 Double Springs
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other Abandonment
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Set drill rig over existing well and started perforating casing with air perforator from top of casing to bottom. Turned perforator 90 degrees and perforated back to surface. Did same operation again for a total of four rows of perforations.</u>				
<u>Ran tremie pipe to bottom of hole with rig, pumped 52 sacks of cement in a neat cement grout into well displacing all water and drill mud. Continued pumping until we had a pure neat cement grout return to the surface</u>				
<u>Waited for one hour and topped off cement.</u>				
<u>See Log # 34686 for orig. completion</u>				

8. WELL CONSTRUCTION

Diameter Unknown inches Total depth 195 feet
Casing record 6 5/8" Steel
Weight per foot _____ Thickness .188
Diameter _____ From _____ To _____
Surface seal: Yes No Type Concrete
Depth of seal Unknown feet
Gravel packed: Yes No
Gravel packed from Unknown feet to _____ feet
Perforations:
Type perforation Factory milled
Size perforation Unknown
From 175 feet to 195 feet

Date started Nov 10, 1990
Date completed Nov 10, 1990

9. WATER LEVEL
Static water level 80 feet below land surface
Flow Unknown G.P.M. _____ P.S.I. _____
Water temperature COOL °F Quality _____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Well abandonment</u>			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP Contractor
Address CARSON CITY, NV 89701 Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources _____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Burt By driller performing actual drilling on site or contractor
Date Nov 13, 1990

BAILER TEST
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours