WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34864
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14472

1. OWNER John Blenkahorn
MAILING ADDRESS P.O. Box 2877, Gardnerville, NV 89410
ADDRESS AT WELL LOCATION Leviathan Mine Road, Gardnerville, NV 89410

2. LOCATION SE ¼ NE ¼ Sec. 22 T. 11 N S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) 35-240-04 (Parcel No.) Double Springs (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden with tight clay		0	7	7
Multi colored clays with small gravels		7	83	76
Small gravels with fine sand. 2 gpm water	xx	83	95	12
Clays with embedded sand and gravels		95	170	75
Volcanic material, fractured, carrying water	xx	170	200	30
Total depth: 200'				

Date started November 13, 19 90
Date completed November 15, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed well with clean water to remove drill cuttings and drill mud. Gravel packed well with pea gravel. Developed well with 250-450 air. Blew 18 gpm from 175'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 inches Total depth 200 feet
inches
inches
Casing record Steel 6 5/8"
Weight per foot 13.03 Thickness .188

Diameter	From	To
6 5/8 inches	2 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 103 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 103 feet to 200 feet

Perforations:
Type perforation Factory Mill Slotted
Size perforation 3" x 3/32"
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 83 feet below land surface
Flow 18 - 20 G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11/16/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627