WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34875
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14471

1. OWNER William & Wanda Stratford GREG DAVIES CONSTRUCTION
MAILING ADDRESS P.O. Box 22
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION
1971 Sorrell
Gardnerville, NV 89410

2. LOCATION SE ¼ NE ¼ Sec. 24 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 29-451-~~14~~ 23 (Parcel No.) Ruehenstroth Flats #2 (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden with clay		0	6	6
Clays with embedded gravels		6	108	102
Black shaley material, hard		102	135	33
Clay, brown, sandy		135	155	20
Gravels with sand, course to med fine	xx	155	180	25
TD: 180'				

'90 NOV 26 A9:08
RECEIVED
STATE ENGINEERS OFFICE

Date started Nov 16, 1990
Date completed Nov 20, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed drill mud and cuttings from well with clean water, gravel packed well and developed with 250 - 450 air for three hours to clean & produce to the maximum capacity of well			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 3/4 inches Total depth 180 feet
9 3/4 inches
inches
Casing record Steel 6 5/8"
Weight per foot 13.03 Thickness .188

Diameter	From	To
6 5/8 inches	2 feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 180 feet

Perforations:
Type perforation Factory Mill Slotted
Size perforation 3" x 3/32"
From 160 feet to 180 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 105 feet below land surface
Flow 25 plus G.P.M. ..... P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. (Contractor)
Address CARSON CITY, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts
By driller performing actual drilling on site or contractor
Date 11/21/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627