

OFFICE USE ONLY  
 Log No. 34885  
 Permit No. 8109  
 Basin. 8109

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 10530

PRINT OR TYPE ONLY

1. OWNER Bently Nevada Corporation ADDRESS AT WELL LOCATION MW 28B  
 MAILING ADDRESS 1617 Water Road Minden, Douglas County, Nevada  
Minden, NV 89423

2. LOCATION NW 1/4 NE 1/4 Sec. 6 T 13 N/S R. 1220 E. Douglas County  
 PERMIT NO. W/O-153A N/A N/A  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  Monitor Well  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<del>Dirt sands black clay silts</del>		0	4	4
<del>Large sm sands</del>		4	5	1
<del>Large sand sm lg gravels</del>		5	31	26
<del>Broken clays silts with gravels</del>		31	43	12
<del>Large gravels</del>		43	49	6
<del>Broken clay silts</del>		49	63	14
<del>Small lg sands sm lg gravels with clay layers</del>		63	82	19
<del>Blue clay with sm gravels</del>		82	86	4
<del>Fine sands</del>		86	88	2

90 NOV 16 AM 29

STATE CONTRACTOR'S BOARD

8. WELL CONSTRUCTION

Diameter 12.25 inches Total depth 86 feet

Casing record 6 5/8 OD 6 ID  
 Weight per foot 17.20 # Thickness .250

Diameter	From	To
<u>6</u> inches	<u>+2.5</u> feet	<u>86</u> feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes  No  Type cement grout  
 Depth of seal 62 feet  
 Gravel packed: Yes  No   
 Gravel packed from 61.5 feet to 86 feet  
Bentonite seal from 61 to 61.5 feet

Perforations:  
 Type perforation Johnson wire wrap screen  
 Size perforation .030"  
 From 71 feet to 86 feet  
 From ..... feet to ..... feet

Date started 10-29 1990  
 Date completed 10-30 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. .... Draw down ..... feet ..... hours  
 G.P.M. .... Draw down ..... feet ..... hours  
 G.P.M. .... Draw down ..... feet ..... hours

9. WATER LEVEL 15 - 20 gpm Airlift  
 Static water level 4.5 feet below land surface  
 Flow ..... G.P.M. .... P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sargent Irrigation Company  
9955 North Virginia Street  
 Address ..... Contractor

Nevada contractor's license number issued by the State Contractor's Board N/A

Nevada contractor's driller's number issued by the Division of Water Resources 1391

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1540

Signed [Signature]  
 By driller performing actual drilling on site or contractor

Date 11-13-90