WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34893
Permit No. 23685
Basin 8-103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15502

1. OWNER STAN SHANE, 301 Montello, ADDRESS AT WELL LOCATION SUTRO RANCH
MAILING ADDRESS Reno Nev. OFF Segale Rd. Dayton, Nev.

2. LOCATION SW ¼ NE ¼ Sec. 12 T. 16 N S R. 21 E. Lyons County
PERMIT NO. 23658 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well ☐ Recondition ☐ Deepen ☐ Other Redrill ☑

4. PROPOSED USE: Domestic ☐ Irrigation ☑ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	1	1
sand		1	26	25
gravel & sand	✓	26	63	37
gravel & cobbels	✓	63	109	46
Cemented sands	✓			
& gravels		109	225	116
Course sand	✓	225	237	12
Cemented sand +	✓	237	272	35
gravel				
Replacing log # 10144				

Date started 8-20, 1990
Date completed 9-20, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1760	3000+-	developed only	

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter 24 inches, 25 inches, inches — Total depth 271 feet

Casing record 56' of 30" 271' of 16"

Weight per foot ..... Thickness .....

Diameter	From	To
30 inches	0 feet	56 feet
inches	feet	feet
16" inches	+2 feet	271 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type 10 sack grout
Depth of seal 56 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 0 feet to 271 feet

Perforations:
Type perforation factory sawed
Size perforation 1/8 x 2 1/2"
From ..... feet to ..... feet
From 171' feet to 271' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level approx. 8 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 80+°F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling inc. (Contractor)
Address 730 Rosewood Dr., Reno, Nev. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board ~~514~~ 14170
Nevada contractor's driller's number issued by the Division of Water Resources 514
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 957
Signed Paul E. Williams (By driller performing actual drilling on site or contractor)
Date 10-1-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627