WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 3490
Permit No.
Basin 6-87

PRINT OR TYPE ONLY

NOTICE OF INT ... 00

1. OWNER JOE IVERSON
MAILING ADDRESS 1616 Oxford Ave.
Sparks, NV 89431

ADDRESS AT WELL LOCATION Mountain RAnch Road/4995 ... Hwy.
Reno, NV 89511

2. LOCATION SW ¼ SW ¼ Sec. 29 26 T 18N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 49-051-41 (Parcel No.) Calahan Ranch Area (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Volcanic boulder		1	15	14
Soft brown sandy clay		15	23	8
Brown clay with smaller boulders		23	34	11
Volcanic boulder		34	41	7
Brown clay with smaller boulders		41	69	28
Granite boulder		69	73	4
Brown clay with gravels & smaller boulders		73	120	47
Soft zone	X	120	149	29
Soft brown sandy clay		149	153	4

Date started 11-6-90, 19
Date completed 11-8-90, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 8 5/8 inches Total depth 153 feet
10 inches 0 to 50 ft.
inches
Casing record 153 ft. steel casing installed.
Weight per foot Thickness .188

Diameter	From	To
6 5/8 inches	0 feet	153 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 153 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 120 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 118 feet below land surface
Flow 46 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date November 13, 1990

STATE ENGINEER
NOV 26 PM 1:11
1990

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85) (O)-627