

OFFICE USE ONLY
 Log No. 34920
 Permit No. _____
 Basin 4-47

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 161,90

1. OWNER Markley Ranch ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS St Rt Jiggo Clark NV 89801

2. LOCATION NW 1/4 SW 1/4 Sec 36 T 30 N R 56 E Clark County _____

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	21	21
Cobbles CLAY		21	75	54
CLAY + SAND		75	101	26
GRAVEL + SAND	X	101	125	24
SANDY - FINE GRAVEL	X	125	158	33
White SANDY CLAY		158	161	3

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 161 feet

Casing record _____ inches _____ inches _____ inches

Weight per foot _____ Thickness 188

Diameter	From	To
<u>6 5/8</u> inches	0 feet	161 feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Resin and T

Depth of seal 103 feet

Gravel packed: Yes No

Gravel packed from 161 feet to 103 feet

Perforations:

Type perforation FACT. CUT

Size perforation 1/8 x 3"

From 121 feet to 161 feet

From _____ feet to _____ feet

Date started 10-4 1990
 Date completed 10-6 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 40 Draw down 7 feet 4 hours

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 49 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature 68.0 °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AAA Drilling Contractor

Address 359 W RIVER ST CLARK NV Contractor

Nevada contractor's license number issued by the State Contractor's Board 20684

Nevada contractor's driller's number issued by the Division of Water Resources 904

Nevada driller's license number issued by the Division of Water Resources the on-site driller 904

Signed Carl Kobayashi
 By driller performing actual drilling on site or contractor

Date 10-16-90