WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34925
Permit No.
Basin 4-48

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 17040

1. OWNER Summit Engineering
MAILING ADDRESS 607 5th St.
Elko, NV 89801

ADDRESS AT WELL LOCATION None

2. LOCATION NW ¼ SE ¼ Sec. 33 T. 34 N/S R. 57 E Elko County
PERMIT NO. M/E-215 (Issued by Water Resources) Parcel No. Spring Creek Mobile Home Section (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soft Sandy Clay		0	9	9
Clay & Rocks		9	13	4
Sandy Clay		13	48	35
Gravel & clay		48	49	1
Sandy clay		49	60	11
Sand w/water	✓	60	60½	½
Sandy clay		60½	68	7½
Sand w/water	✓✓	68	71	3
Gravel & Sand	✓✓	71	75	4
Sandy clay		75	82	
T.D. 82				



Date started 11/8, 1990
Date completed 11/9, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 82 feet
inches
inches
Casing record 82 ft x 2" PVC
Weight per foot ..... Thickness .....

Diameter	From	To
2 inches	+1 feet	82 feet
inches	feet	feet
6" inches (steel)	+1 feet	1 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement 35'
Depth of seal Bentonite 5 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 40 feet to 82 feet

Perforations:
Type perforation Screen
Size perforation .020
From 45 feet to 75 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 50 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Muth Drilling Co. (Contractor)
Address 203 Pine St. 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada contractor's driller's number issued by the Division of Water Resources 632
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed James V. Muth (By driller performing actual drilling on site or contractor)
Date 11/14/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O) 627