WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

Deepen # 34928

OFFICE USE ONLY
Log No. 34318
Permit No.
Basin 4-40

NOTICE OF INTENT NO. 13182

1. OWNER Melvin Knudsen
MAILING ADDRESS Osino Rt. 163-2 Elko, NV 89801
ADDRESS AT WELL LOCATION MVR Unit 3 Lot 7 Blk 55, Meadow Valley Ranchos Elko, NV 89801

2. LOCATION NW ¼ NW ¼ Sec. 9 T. 35 N/S R. 56 E Elko County
PERMIT NO. N/A (Issued by Water Resources) 35-055-07-8 (Parcel No.) Meadow Valley Ranchos (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Large gravel		0	9	
Small boulders & Large gravels con.		9	30	
Brown Clay & Sand		30	35	
Semi-Con. gravels, Sand & Silt		35	110	
Sand & gravels	small amt.	110	115	
Semi Con. gravels, silts & sands		115	140	
Brown Silts & sands	small amt.	140	150	
Coarse gravels		150	200	
Coarse gravels & small boulders		200	230	
10/90		230	236	

RECEIVED AUG 8 '90 9:54 AM STATE ENGINEER'S OFFICE

Date started 7-25, 19 90
Date completed 7-29, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 230 feet
6 1/4 inches 236 10/90
inches
Casing record
Weight per foot ..... Thickness .188

Diameter	From	To
6 5/8 inches	+2 feet	228 feet
inches	feet	feet
5 inches	216 feet	236 feet 10/90
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 230 feet

Perforations:
Type perforation air
Size perforation 1/8" x 1" (4 per foot)
From 180 feet to 220 feet
From ..... feet to ..... feet
From 3 tackout 216 feet to 236 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 140 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name R.D. Reynolds Drilling (Contractor)
Address Box 402, Wells, NV 89835 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 014410
Nevada contractor's driller's number issued by the Division of Water Resources 1390
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1585
Signed Russell Boley (By driller performing actual drilling on site or contractor)
Date 8-1-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY 10)-627