

OFFICE USE ONLY
 Log No. 34965
 Permit No. _____
 Basin 3-40

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1975

PRINT OR TYPE ONLY

1. OWNER Steve Boies ADDRESS AT WELL LOCATION Rural - Hubbard Ranch
 MAILING ADDRESS Wells, NV 89835 No. of Wells on 5-13
 2. LOCATION SE 1/4 NW 1/4 Sec 11 T 43 N/S R. 63 E EIKO County _____
 PERMIT NO. N/A Parcel No. N/A Subdivision Name _____
Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	5	
Gravels		5	15	
Large Gravels semi.		15	19	
Brown Sand		19	25	
Large Gravels semi.		25	30	
Brown Sand & Clay		30	37	
Gravels & Sand		37	45	
ALT. Layers Gravels				
& Sand		45	70	
ALT. Layers Gravels				
semicon. to				
uncon.		70	100	
ALT. Layers Sandstone				
(soft) silts &				
Gravels		100	170	

8. WELL CONSTRUCTION
 Diameter 10 inches Total depth 171 feet
 _____ inches
 _____ inches
 Casing record _____
 Weight per foot _____ Thickness .188

Diameter	From	To
<u>6.78</u> inches	<u>7.2</u> feet	<u>171</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 171 feet
 Perforations:
 Type perforation air
 Size perforation 1" x 1/8" 4 rows, 39 slots/row
 From 150 feet to 160 feet
 From _____ feet to _____ feet

NOV 26 12:11
 STATE ENGINEERS OFFICE

Date started October 10 1990
 Date completed October 15 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 20 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name R.D. Reynolds Drilling Contractor
 Address P.O. Box 402 Wells, NV 89835 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 014410
 Nevada contractor's driller's number issued by the Division of Water Resources 1390
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1585
 Signed Kuss Boies
By driller performing actual drilling on site or contractor
 Date 11/14/90