

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 15190

PRINT OR TYPE ONLY

1. OWNER Nate Lising ADDRESS AT WELL LOCATION 626 HWY 88  
 MAILING ADDRESS PO Box 282  
GARD NV 89410  
 2. LOCATION SE 1/4 NE 1/4 Sec. 25 T. 12 N/S R. 19 E. Douglas County  
 PERMIT NO. 19-260-13 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	10	
SAND (DG)	X	10	25	
GRAY SAND		25	35	
SAND		35	75	
SAND & Gravel		75	80	
SAND		80	100	
SAND & Gravel		100	105	
SAND		105	120	
Rock & Gravel		120	130	
SAND & Gravel		130	145	
SAND Rock & Gravel		145	170	
SAND & Gravel		170	195	
SAND	X	195	200	
SAND rocks & Gravel		200	215	
SAND		215	220	
Rock & Gravels		220	235	
SAND		235	245	
SAND & Gravels		245	255	
CLAY SAND		255	300	

NO DEE 10 AM 54  
 WERE VIEWED  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Diameter 12 inches Total depth 175 feet  
8 inches Hold depth 300'  
 inches

Casing record ASTM 1053A 20' X 1.88 X  
 Weight per foot \_\_\_\_\_ Thickness 1.88

Diameter	From	To
8 inches	0 feet	175 feet
6 inches	160 feet	300 feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type NEAT GUMST  
 Depth of seal 100 feet  
 Gravel packed: Yes  No   
 Gravel packed from 175 feet to 100 feet

Perforations:  
 Type perforation HAND-CUT/TOOTH  
 Size perforation 4 ROWS 8" X 3/16" 20 Slots  
 From 8" 133 feet to 173 feet  
 From 6" 160 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 10-25 19 90  
 Date completed 11-10 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>AIR</u>	<u>APPROX. 150 gpm +/-</u>		<u>4hrs.</u>
	<u>Artesian flow - 25 gpm</u>		

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL

Static water level Artesian Flow feet below land surface  
 Flow 25 G.P.M. P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Kauchack Drilling Inc. Contractor  
 Address 2668 Keller Minden NV 89423 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board #022268  
 Nevada contractor's driller's number issued by the Division of Water Resources #7380  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #7495  
 Signed Michael Allen By driller performing actual drilling on site or contractor  
 Date 11-12-90