WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34967
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14612

1. OWNER Kirk Johnson
MAILING ADDRESS P.O.Box 2435
Gardnerville Nev. 89410

ADDRESS AT WELL LOCATION 613 Stallion Ct.
Gardnerville, Nev 89410

2. LOCATION SE ¼ SW ¼ Sec. 24 T. 12N N/S R. 20E E Douglas County
PERMIT NO. (Issued by Water Resources) 29-520-30 (Parcel No.) Rouenstroth Estates (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, sandy		0	23	23
Conglomerate		23	31	8
Gravel		31	65	34
Clay		65	81	16
Gravel		81	104	23
Clay, sandy		104	109	5
Gravel	X	109	150	41

91 JAN -2 AM 10:10
RECEIVED
STATE ENGINEERS OFFICE

Date started 12-7, 19 90
Date completed 12-14, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Airlift	18		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼" 0-50' inches Total depth 150 feet
8 3/4" 50-150' inches
..... inches
Casing record 6 5/8"
Weight per foot 12.92 Thickness 0.188"

Diameter	From	To
6 5/8" inches	0 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type Concrete
Depth of seal 50' feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 150 feet

Perforations:
Type perforation Factory
Size perforation 3/32" X 3"
From 120 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 90 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pre-Cambrian Drilling Co. Inc (Contractor)
Address 794 Foothill Rd. Gardnerville, Nv. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 30267
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
Signed ..... (By driller performing actual drilling on site or contractor)
Date ~~XXXX~~ 12-18-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627