WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34969
Permit No.
Basin 8-109

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14592

1. OWNER Gregory Hill
MAILING ADDRESS P.O.Box 2606 Minden Nev. 89423
ADDRESS AT WELL LOCATION 1933 Morgan Ct. Gardnerville, Nev. 89410

2. LOCATION NE ¼ NE ¼ Sec. 25 T 12N N/S R. 20E E Douglas County
PERMIT NO. (Issued by Water Resources) 29-092-04 (Parcel No.) Rouenstroth Estates (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders		0	10	10
Clay		10	14	4
Gravel		14	126	112
Clay		126	152	26
Gravel		152	170	18
Clay, Sandy		170	246	76
Gravel		246	265	19
Clay	X	265	287	22
Rock & Gravel	X	287	360	73

RECEIVED '90 DEC 20 A10:34 STATE ENGINEERS OFFICE

Date started 11-16, 1990
Date completed 11-28, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Airlift	20		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10" 0-50' inches Total depth 360 feet
8 3/4" 50'-360' inches
..... inches
Casing record 6 5/8"
Weight per foot 12.92 Thickness 0.188

Diameter	From	To
6 5/8" inches	0 feet	360 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 360 feet

Perforations:
Type perforation Factory
Size perforation 3/32" X 3"
From 300 feet to 320 feet
From 340 feet to 360 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 250 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pre-Cambrian Drilling Co. Inc. (Contractor)
Address 794 Foothill Rd. Gardnerville, Nv. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 30267
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
Signed ..... (By driller performing actual drilling on site or contractor)
Date 12-2-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627