

WELL #1

WHITE—DIVISION OF WATER RESOURCES  
 CANARY—CLIENT'S COPY  
 PINK—WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 31972  
 Permit No. 54842  
 Basin 9-108

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15721

1. OWNER PERRI & SONS FARM, INC. ADDRESS AT WELL LOCATION KERMETTI & MCKENZIE LANE YERINGTON  
 MAILING ADDRESS 430 HWY 339  
YERINGTON, NV 89447  
 2. LOCATION SE 1/4 NW 1/4 Sec 36 T 13 S R. 25 E LYON County  
 PERMIT NO. 54842 12-151-07011-02 AGRICULTURAL 159.082 ACRES  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN CLAY-TOP SOIL		0	7	7
SANDY BROWN CLAY		7	15	8
SAND & GRAVEL		15	30	15
HARD SANDY BROWN CLAY		30	53	23
COARSE SAND & GRAVEL		53	63	10
SANDY CLAY		63	73	10
COARSE SAND & GRAVEL		73	90	17
SANDY CLAY	X	90	107	17
COARSE SAND & GRAVEL W/S				
CLAY STRINGERS	X	107	260	153
LARGE ROCKS IN SANDY				
BROWN CLAY	X	260	295	35
LARGE GRANIT ROCKS IN				
BROWN CLAY		295	300	5

91 JAN -3 AMO 110  
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Diameter.....inches Total depth 300 feet  
36 inches to 100'  
24 inches to 300'

Casing record.....16"  
 Weight per foot..... Thickness 1/4

Diameter	From	To
16" BLANK.....inches	0 feet	100 feet
.....inches	.....feet	.....feet

Surface seal: Yes  No  Type GROUT  
 Depth of seal.....100 feet  
 Gravel packed: Yes  No   
 Gravel packed from.....50 feet to.....300 feet

Perforations:  
 Type perforation.....100-250 ROSCO MOSS FF  
 Size perforation.....DBL ROW SLOT 1/8 X 3  
 From.....100 feet to.....250 feet  
 From.....250 feet to.....290 feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet

Date started.....OCTOBER 20 19 90  
 Date completed.....NOVEMBER 1 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>4000</u>	<u>118.6</u>	<u>0</u>

BAILER TEST

G.P.M. .... Draw down.....feet .....hours  
 G.P.M. .... Draw down.....feet .....hours  
 G.P.M. .... Draw down.....feet .....hours

9. WATER LEVEL

Static water level.....36.9 feet below land surface  
 Flow.....G.P.M. .... P.S.I.  
 Water temperature.....COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name.....Humboldt Drilling & Pump Co., Inc.  
 Address.....P.O. Box 592 Wmca., NV 89445  
 Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada contractor's driller's number issued by the Division of Water Resources.....1154  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller.....795  
 Signed.....[Signature]  
 by driller performing actual drilling on site or contractor  
 Date.....12-12-90