

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 14466

PRINT OR TYPE ONLY

1. OWNER JOHN KORB ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Box 2919 20 Maranatha  
Carson City, NV 89702 Carson City, NV 89704  
 2. LOCATION NE 1/4 NW 1/4 Sec 3 T. 17 N. S. R. 19 E Washoe County  
 PERMIT NO. 46-031-30 None Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Large boulders with DG sand		0	130	130
Clay seam, grey		130	134	4
Fractured granite with water/ Major water at 163-64 and 185-87	xxxx	134	200	66
TD 200ft				

8. WELL CONSTRUCTION

Diameter 11 3/4 inches Total depth 200 feet  
9 3/4 inches  
 inches

Casing record Steel 6 5/8"  
 Weight per foot 13.03 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>12</u> feet	<u>200</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes  No  Type Concrete  
 Depth of seal 100 feet  
 Gravel packed: Yes  No   
 Gravel packed from 100 feet to 200 feet

Perforations:  
 Type perforation Factory Mill Slot  
 Size perforation 3" x 3/32"  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started Nov 27, 1990  
 Date completed Dec 1, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Flushed well with clean water to remove drill mud and develop well. Gravel packed well and developed well with 250-450 air. Blew 25 plus gpm from 80 feet for three hours.</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Flow 25 plus G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A & H PUMP CO. Contractor  
 Address CARSON CITY, NV 89701 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 23295  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674  
 Signed Jerry Bush  
By driller performing actual drilling on site or contractor  
 Date Dec 3, 1990