

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 15403

PRINT OR TYPE ONLY

1. OWNER DR GARY TOOGOOD ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 8500 Bellhaven  
Reno, NV 89511  
 2. LOCATION NE 1/4 NE 1/4 Sec. 11 T. 18 N. N/S R. 19E E. Washoe County  
 PERMIT NO. 041-130-05 Bellhaven Estates  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Bottom of hole at 200 ft.		Open hole from		
200 ft. to 239 ft.	11.3 GPM at	239 ft.		
Brown volcanic rock		239	242	3
Brown soft clay		242	244	2
Brown volcanic rock		244	290	46
Brown rusty volcanic rock		290	318	28
Brown volcanic rock		318	323	5
Fracture rock	X	323	327	4
Softer brown volcanic rock		327	352	25

90 DEC 14 AM 1:39  
 RECEIVED  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Diameter 6 1/8 inches Total depth 352 feet  
 Casing record 352' steel casing installed  
 Weight per foot 188 Thickness \_\_\_\_\_  
 Diameter From To  
5" OD inches 0 feet 352 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type N/A  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from 200 feet to 352 feet  
 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 84 feet to 94 feet  
 From 154 feet to 164 feet  
 From 244 feet to 264 feet  
 From 324 feet to 344 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 11-28-90, 19\_\_\_\_  
 Date completed 11-30-90, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 33 feet below land surface  
 Flow 35 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne DRilling, Inc.  
 Contractor  
 Address P.O. Box 12370, Reno, NV 89510  
 Contractor  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 908  
 issued by the Division of Water Resources  
 Nevada driller's license number 923  
 issued by the Division of Water Resources, the on-site driller  
 Signed Wayne C. Feldman  
 \_\_\_\_\_ driller performing actual drilling on site or contractor  
 Date December 4, 1990