WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 34997
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11313

1. OWNER EDWIN McBROOME
MAILING ADDRESS P. O. Box 625
Fallon, Nv. 89406

ADDRESS AT WELL LOCATION
3700 Keyes Dr.
Fallon, Nv.

2. LOCATION NE ¼ SW ¼ Sec. 8 T. 18 N/S R. 28 E Churchill County
PERMIT NO. N/A (Issued by Water Resources) | 4 (Parcel No.) | Mills, Newell (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Coarse Sand		3	18	15
Brown Clay		18	21	3
Brown Sand		21	25	4
Coarse Brown Sand		25	33	8
Green Sand		33	42	9
Green Coarse Sand		42	45	3
Green Sandy Clay		45	48	3
Brown Clay		48	49	1
Brown Sand		49	50	1
Coarse Brown Sand	X	50	53	3
Green Sand		53	54	1

'90 DEC 10 A11:51
RECEIVED
STATE ENGINEER'S OFFICE

Date started December 3, 19 90
Date completed December 3, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 54 feet
..... inches
..... inches
Casing record ASTM-A-53-A
Weight per foot 12.92 Thickness .188

Diameter	From	To
6 5/8 inches	0 feet	54 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 54 feet

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 51 feet to 54 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 9 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P. O. Box 1265, Fallon, Nv. 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada contractor's driller's number issued by the Division of Water Resources 1454
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Douglas Parsons (By driller performing actual drilling on site or contractor)
Date Dec 6, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627