WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35002
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11317

1. OWNER Ed Perkins/Dan Organ P & O Development
MAILING ADDRESS 2152 Reno Hwy Fallon, Nevada 89406

ADDRESS AT WELL LOCATION Perazzo Ln. Fallon, Nevada 89406

2. LOCATION NE ¼ NE ¼ Sec. 24 T 19 N/S R 29 E Churchill County
PERMIT NO. N/A (Issued by Water Resources) | 4 (Parcel No.) | Don Organ & Ed Perkins (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fine sand | | 0 | 6 | 6 |
| Coarse sand | | 6 | 17 | 11 |
| Brown clay | | 17 | 21 | 4 |
| Green clay | | 21 | 42 | 21 |
| Green & Black clay | | 42 | 47 | 5 |
| Green & Brown Clay | | 47 | 72 | 25 |
| Brown clay | | 72 | 74 | 2 |
| Coarse Brown sand | X | 74 | 79 | 5 |
| Green clay | | 79 | 80 | 1 |

RECEIVED '90 DEC 10 AM 11:51 STATE ENGINEER'S OFFICE

Date started Nov. 27, 19 90
Date completed Nov. 27, 19 90

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 80 feet
..... inches
..... inches
Casing record ASTM-A-53-A
Weight per foot 12.92 Thickness .188

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 0 feet | 80 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 80 feet

Perforations:
Type perforation Millcut
Size perforation 1/8"
From 77 feet to 80 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 11 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P. O. Box 1265, Fallon, Nv. 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada contractor's driller's number issued by the Division of Water Resources 1454
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Douglas Parsons (By driller performing actual drilling on site or contractor)
Date Dec 6, 1990

(Rev. 11 85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627