WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35006
Permit No.
Basin B-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13990

1. OWNER City of Fallon
MAILING ADDRESS 55 Williams Ave.
Fallon, Nevada

ADDRESS AT WELL LOCATION Harigan Road
Fallon, Nevada

2. LOCATION NW ¼ SW ¼ Sec. 32 T. 19N N/S R. 29 E. Churchill County
PERMIT NO. Waiver M/O-322 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Grey brown silty sand		0	8	8
White brown sand		8	18	10
Grey brown silty sand		18	26	8
Grey sand		26	49	23
Black sandy silt		49	51	3
Black silty sand		51	55	4
Black sandy silt		55	56	1
Black silty sand		56	60	4
Black sandy silt		60	61	1

90 DEC 13 AM 8:36
RECEIVED
STATE ENGINEER

Date started 11-14, 1990
Date completed 11-17, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	N/A		

BAILER TEST
G.P.M. N/A Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 55 feet
..... inches
..... inches
Casing record Sch 40 PVC
Weight per foot N/A Thickness N/A

Diameter	From	To
4 inches	0 feet	55 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement Slurry
Depth of seal 4ft feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 5 feet to 55 feet

Perforations:
Type perforation machine cut slot
Size perforation 0.02
From 5 feet to 55 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 12 feet below land surface
Flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Exploration Drilling (Contractor)
Address 1635 Belford Rd, Reno, NV 89509 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1028
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12/5/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627