

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14632

1. OWNER Springwood/ Bighorn / Washoe County ADDRESS AT WELL LOCATION Pyramid Lake Highway
 MAILING ADDRESS 901 N Stewart St
Carson City, NV 89701

2. LOCATION SE 1/4 SW 1/4 Sec 3 T 20 N/S R. 20 E Washoe County Washoe
 PERMIT NO. 52524/52588-89-150-72 Spanish Springs
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. Monitor
 Domestic
 Municipal

PROPOSED USE
 Irrigation
 Industrial

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|------|-----|------------|
| Tan clay tan white brown yellow D.G | | 0 | 25 | 25 |
| Coarse gravel green brown yellow | | 25 | 27 | 2 |
| Tan clay traces of sand | | 27 | 30 | 3 |
| Green brown tan yellow sands with tan clay zones 1 - 3' intervals | | 30 | 74 | 44 |
| Multi-colored sands & gravels with tan clay zones | | 74 | 323 | 249 |
| T.D. 323 ft | | | | |

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 200 feet

Casing record 2 inch Sch 80 PVC
 Weight per foot Sch 80 Thickness _____

| Diameter | From | To |
|-----------------|----------------|-----------------|
| <u>2</u> inches | <u>+1</u> feet | <u>200</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 200 feet

Perforations:
 Type perforation 1/8" saw slot
 Size perforation 1/8"
 From 110 feet to 190 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 7/20/90, 19____
 Date completed 9/18/90, 19____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|--------------------|--------|-----------|------------------|
| Developed air lift | | | |
| | | | |
| | | | |

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 51 feet below land surface
 Flow 20 G.P.M. P.S.I. _____
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L Sparks
 Contractor 89431

Nevada contractor's license number issued by the State Contractor's Board 15291
 Nevada contractor's driller's number issued by the Division of Water Resources 1132
 Nevada driller's license number issued by the Division of Water Resources 1511
 Division of Water Resources the on-site driller

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 9/