WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 35010
Permit No.
Basin 7-92a

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1325

1. OWNER Permody Properties
MAILING ADDRESS 1200 Financial Blvd Reno, NV 89510
ADDRESS AT WELL LOCATION Moya Bl. Steel NEV,

2. LOCATION NW ¼ SE ¼ Sec. 30 T. 21 N/S R. 19 E. Washoe County
PERMIT NO. M/O-303 (Issued by Water Resources) NA (Parcel No.) NA (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☒ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☒ Industrial ☑ Stock ☐
Monitoring

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☑ Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sargent Drilling set surface casing to 24 feet (previous report) | | 0 | 24 | |
| | | (log#34795) | | |
| Brown fine-med sand | | 24 | 34.5 | 10.5 |
| increasing fines | | 34.5 | 36 | 15 |
| med-coarse silty sands | | 36 | 37 | 1 |
| Silty sands 30% fines | | 37 | 42 | 5 |

'90 DEC 13 A10:36
RECEIVED
STATE ENGINEERS OFFICE

Date started 11-5, 1990
Date completed 11-6, 1990

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | N/A | | |

BAILER TEST
G.P.M. N/A Draw down ..... feet ..... hours
G.P.M. Draw down ..... feet ..... hours
G.P.M. Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 42 feet
..... inches
..... inches
Casing record Sch 40 PVC
Weight per foot N/A Thickness N/A

| Diameter | From | To |
|---|---|---|
| 2 inches | 0 feet | 42 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type grout
Depth of seal 29 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 29 feet to 42 feet

Perforations:
Type perforation Factory Slot
Size perforation 0.02
From 32 feet to 42 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 13 feet below land surface
Flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature] Contractor
Address 1635 Belford RD Reno NEV, Contractor
Nevada contractor's license number issued by the State Contractor's Board
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] By driller performing actual drilling on site or contractor
Date 11/20/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627