WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35068
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16423

1. OWNER Pete Rogers (Builder)
MAILING ADDRESS P.O. Box 229 Genoa NV
ADDRESS AT WELL LOCATION 2485 Second Terrace Gardnerville, NV 89410

2. LOCATION SE ¼ NW ¼ Sec. 33 T. 13 N/S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) 23-160-11 (Parcel No.) NONE (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	5'	5'
Cemented Gravel		5'	80'	75'
Clay		80'	97'	17'
Cemented Gravel		97'	180'	83'
Gravel w/water	X	180'	220'	40'
TD 220				

'91 JAN 22 A8:28
RECEIVED STATE ENGINEERS OFFICE

Date started 1-12, 1991
Date completed 1-15, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow Well With Air			
Well Making 20+ GPM			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 3/4 inches Total depth 220' feet
..... inches
..... inches
Casing record Steel 6 5/8
Weight per foot 13.03 Thickness .188

Diameter	From	To
6 5/8 inches	0 feet	160' feet
inches	200' feet	220' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement Grout
Depth of seal 100 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 100 feet to 220' feet

Perforations:
Type perforation Mill Slot
Size perforation 3/32 X 3 1/2
From 160' feet to 220' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 60 feet below land surface
Flow 20+ G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+H Pump Co. (Contractor)
Address 5551 Hy St East CC NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts (By driller performing actual drilling on site or contractor)
Date 1-16-1991

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627