

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 15423

1. OWNER CARSON CITY ADDRESS AT WELL LOCATION WINNIE LANE
MAILING ADDRESS 3302 BUTTE WAY CARSON CITY
CARSON CITY, NV 89701

2. LOCATION NE 1/4 SE 1/4 Sec. 12 T. 15 N/S R. 19 E CARSON County
PERMIT NO. 23672 & 23673 8-272-99 Parcel No. N/A Subdivision Name

3. TYPE OF WORK REDRILL
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock Other

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BLOW SAND W/S GRAVEL & TRACE OF CLAY		2	5	5
DECOMPOSED GRANIT		5	12	7
DECOMPOSED GRANIT W/S CLAY		12	27	15
DECOMPOSED GRANIT W/S COBBLES & CLAY		27	42	15
DECOMPOSED GRANIT		42	65	23
DECOMPOSED GRANIT W/S BOULDERS		65	70	5
DECOMPOSED GRANIT W/S COBBLES & CLAY		70	81	11
DECOMPOSED GRANIT W/S COBBLES		81	101	20
DECOMPOSED GRANIT W/S CLAY		101	105	5
GRANIT BOULDERS W/S CLAY		105	135	29
DECOMPOSED GRANIT		135	141	6
DECOMPOSED GRANIT W/S CLAY				
SPRINGERS		141	182	41
BOULDERS W/S DECOMPOSED GRANIT		182	190	8
DECOMPOSED GRANIT W/S CLAY				
SPRINGERS		190	223	33
FRACTURED GRANIT	X	223	430	277

8. WELL CONSTRUCTION

Diameter..... inches Total depth..... 480 feet
30 inches to 50'
24 inches to 480'

Casing record..... 16 & 10 26" conductor to 50'
 Weight per foot..... Thickness 1/4 WALL

Diameter	From	To
16" BLANK inches	2	203
16" X 10" REDUCER	203	205
10" BLANK inches	255	270
10" BLANK inches	310	325
10" BLANK inches	345	365
10" BLANK inches	385	397

Surface seal: Yes No Type..... GROUT
 Depth of seal..... 50 feet
 Gravel packed: Yes No
 Gravel packed from..... 0 feet to..... 397 feet

Perforations:
 Type perforation..... JOHNSON SCREEN
 Size perforation..... 10" 100 SLOT WIRE WRAP
 From..... 225 feet to..... 255 feet
 From..... 270 feet to..... 310 feet
 From..... 325 feet to..... 345 feet
 From..... 365 feet to..... 385 feet
 From..... feet to..... feet

Date started..... NOVEMBER 26 19 90
 Date completed..... NOVEMBER 26 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>1000</u>	<u>16</u>	<u>72</u>

BAILER TEST

G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours

9. WATER LEVEL

Static water level..... 93.7 feet below land surface
 Flow..... G.P.M. P.S.I.
 Water temperature..... COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
 Address..... P.O. Box 592 Wmca., NV 89445
 Nevada contractor's license number issued by the State Contractor's Board..... 015234
 Nevada contractor's driller's number issued by the Division of Water Resources..... 1154
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller..... 1440
 Signed..... [Signature]
 Date 1-3-91