WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35162
Permit No.
Basin 9-107

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16372

1. OWNER FN Fulstone Inc, Ranches
MAILING ADDRESS P.O. Box 61
Smith Valley, NV 89430

ADDRESS AT WELL LOCATION: 3/4 mile east of Smith, Lyon County, Nevada - Hwy 208

2. LOCATION SW ¼ NW ¼ Sec. 20 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. N/A Issued by Water Resources
N/A Parcel No. 10-511-07
N/A Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil-Sand		0	7	7
Sand-S gravel-little clay		7	40	33
Sand-gravel		40	100	60
Grey clay-little sand		100	140	40
Brown clay-sand		140	160	20
Gravel-sand		160	190	30
Little clay		190	210	20
Sand-clay		210	260	50

'91 FEB -7 A10:26
STATE ENGINEER'S OFFICE

Date started 01-28, 1991
Date completed 01-29, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12.25 inches Total depth 260 feet
..... inches
..... inches
Casing record 6 x .188
Weight per foot 12.81# Thickness .188

Diameter	From	To
6 inches	+2 feet	260 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes XX ☐ No ☐ Type cement grout
Depth of seal 53 feet
Gravel packed: Yes XX ☐ No ☐
Gravel packed from 53 feet to 260 feet

Perforations:
Type perforation factory slot-double perf
Size perforation .125" x 3"
From 60 feet to 260 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 63 feet below land surface
Flow 30 G.P.M. Airlift P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sargent Irrigation Company Contractor
Address 9955 North Virginia Street Contractor
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ~~1540~~ 1541
Signed [signature] By driller performing actual drilling on site or contractor
Date 2-6-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627