

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 16302

PRINT OR TYPE ONLY

1. OWNER Wastwicks Coast ADDRESS AT WELL LOCATION 2630 L. Wade  
MAILING ADDRESS 1870 Halman  
Case No 89710

2. LOCATION SW 1/4 SW 1/4 Sec 34 T. 14 N/S R. 20 E County Clark  
PERMIT NO. 21-221-04 Parcel No. \_\_\_\_\_ Subdivision Name Thomas R.  
Issued by Water Resources \_\_\_\_\_

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND</u>		<u>0</u>	<u>20</u>	
<u>SAND &amp; Gravel</u>		<u>20</u>	<u>25</u>	
<u>SAND</u>		<u>25</u>	<u>30</u>	
<u>SAND &amp; Gravel</u>		<u>30</u>	<u>35</u>	
<u>SAND &amp; Silt</u>	<input checked="" type="checkbox"/>	<u>35</u>	<u>35</u>	
<u>SAND silt &amp; CLAY</u>	<input checked="" type="checkbox"/>	<u>35</u>	<u>100</u>	
<u>SAND CLAY &amp; Gravel</u>	<input checked="" type="checkbox"/>	<u>100</u>	<u>115</u>	
<u>SAND CLAY &amp; pebbles</u>	<input checked="" type="checkbox"/>	<u>115</u>	<u>125</u>	
<u>SAND &amp; CLAY &amp; Gravel</u>	<input checked="" type="checkbox"/>	<u>125</u>	<u>160</u>	

91 JAN 30 AM 10:00 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Diameter 12 inches Total depth 160 feet  
Casing record ASTM 103A  
Weight per foot \_\_\_\_\_ Thickness 188  
Diameter \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_ feet  
Surface seal: Yes  No  Type Concrete  
Depth of seal 50 feet  
Gravel packed: Yes  No   
Gravel packed from 160 feet to 50 feet

Perforations:  
Type perforation Factory Reel  
Size perforation 3" 1/8 x 100"  
From 160 feet to 140 feet

Date started 1-8 1991  
Date completed 1-11 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>AIR</u>	<u>25-30+</u>		

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 60 feet below land surface  
Flow 25-30+ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 60 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge

Name Kauchack Drilling Inc Contractor  
Address 2668 Fuller Minden NV Contractor  
Nevada contractor's license number issued by the State Contractor's Board #021268  
Nevada contractor's driller's number issued by the Division of Water Resources #1380  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #4455  
Signed Michael Allen  
By driller performing actual drilling on site or contractor  
Date 1-14-91