WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35175
Permit No.
Basin 8-104

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16487

1. OWNER JEFF HOUK
MAILING ADDRESS 23 Bellvue Road
Carson City, NV 89704 T.16 N.

ADDRESS AT WELL LOCATION
4225 Eastlake Blvd
Carson City, NV 89704

2. LOCATION SW ¼ NE ¼ Sec. 5 T. ~~15~~ N/S R. 20 E. Washoe County
PERMIT NO. Issued by Water Resources
50-435-20 Parcel No.
New Washoe City #5 Lot 32 Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☒
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Ran scrubber brush				
in well to bottom to				
clean out perforations				
Cleaned well to bottom				
Blew well for two hours				
to blow out sand and				
stagnent water.				
Well depth is still the depth that it was				
originally drillled.				
TD of well is 150 feet				

91 FEB -4 10:21
STATE ENGINEER

Date started Jan 30, 19 91
Date completed Jan 30, 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well to clean and develop for 2 hours			
from 140 ft. Blew 15 gpm from 140 ft.			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 5/8" OD inches Total depth 150 feet
inches
inches
Casing record Steel 6 5/8"
Weight per foot 13.03 Thickness .188

Diameter	From	To
6 5/8 inches	42 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal Unknown feet
Gravel packed: Yes ☐ No ☐ Unknown
Gravel packed from feet to feet

Perforations:
Type perforation Unknown
Size perforation Unknown
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 82 feet below land surface
Flow 15 G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. Contractor
Address Carson City, NV 89701 Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed [signature] By driller performing actual drilling on site or contractor
Date Jan 31, 1991

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627