

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 17047

PRINT OR TYPE ONLY

1. OWNER GUND RANCH #3 ADDRESS AT WELL LOCATION GUND RANCH  
 MAILING ADDRESS LEE, N.Y. 89829 LEE, N.Y. 89821

2. LOCATION NW 1/4 NE 1/4 Sec 28 T. 2031 N. 3457 E. ELKO, Co. County  
 PERMIT NO. None Parcel No. N.A. 172 Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE Replacement  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Clay sand, gravel, cobbles &amp; boulders</u>		<u>0</u>	<u>31</u>	<u>31</u>
<u>Clay &amp; gravel</u>	<u>Scap</u>	<u>31</u>	<u>43</u>	<u>12</u>
<u>Clay, sand, gravel, cobbles &amp; boulder</u>		<u>43</u>	<u>220</u>	<u>177</u>
<u>Soft crumbly sandstone with water very fine sand</u>		<u>220</u>	<u>240</u>	<u>20</u>
<u>Clay &amp; gravel in streaks w/water @</u>		<u>240</u>	<u>362</u>	<u>122</u>
		<u>243</u>	<u>248</u>	<u>5</u>
		<u>282</u>	<u>292</u>	<u>10</u>
		<u>305</u>	<u>306</u>	<u>1</u>
		<u>320</u>	<u>321</u>	<u>1</u>
		<u>345</u>	<u>346</u>	<u>1</u>
	<u>T.D.</u>	<u>352 ft.</u>		

8. WELL CONSTRUCTION  
 Diameter 10 inches Total depth 352 feet  
8 inches  
6 inches  
 Casing record 353.6 6 9/8 steel  
 Weight per foot 17.02 Thickness .250  
 Diameter From To  
6 9/8 inches +1.5 feet .250 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Cement grout  
 Depth of seal 6.5 feet  
 Gravel packed: Yes  No   
 Gravel packed from 65 feet to 352 feet  
 Perforations:  
 Type perforation Touch cut  
 Size perforation 1/16 & 1/4"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 243 feet to 263 feet  
 From 282 feet to 352 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 12-11- 1990  
 Date completed 1-29 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
 Static water level 182 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Muth Drilling Co Contractor  
 Address 203 Pine St, ELKO 89801 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 10819  
 Nevada contractor's driller's number issued by the Division of Water Resources 632  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632  
 Signed James V. Muth By driller performing actual drilling on site or contractor  
 Date 2/24/91

BAILER TEST  
 G.P.M. 30 Draw down 100 feet 4 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours