WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35210
Permit No. 52520
Basin 219

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER Moapa Valley Water District
MAILING ADDRESS P.O. Bx 257
Logandale Nv. 89021

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NE ¼ Sec. 7 T. 14S N/S R. 65E E. MDB&M CLARK County
PERMIT NO. 52520 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobble Stone		0	26	26'
Clay & Sand		26	66	40'
Cobble & Sand		66	80	14'
Cemented Gravels		80	460	380'
Bedrock		460	565	105'
Note: Hit Fault At 503' to 565'				

RECEIVED
MAR 19 1991
Div. of Water Resources
Branch Office Las Vegas, NV

Date started Sept 3rd, 1990
Date completed Jan 25, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	3795	30'	35 HRS
	4500	39	1 HR

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 18 inches Total depth 565 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness

Diameter	From	To
16 inches	0 feet	195 feet
14 inches	195 feet	205 feet
14 inches	255 feet	265 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 120' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation
Size perforation
From 205 feet to 255 feet Mill SLOT
From 265 feet to 315 feet Mill SLOT
From 315 feet to 565 feet SCREEN
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 44.8' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 90 °F Quality 596 DS Ph 7.93

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A&A Pump & Drilling (Contractor)
Address Star Route Bx 21-D (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0018239
Nevada contractor's driller's number issued by the Division of Water Resources 811
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 811
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2/18/91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627