WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

in Book

OFFICE USE ONLY
Log No. 35237
Permit No.
Basin 162

NOTICE OF INTENT NO. 8019

1. OWNER Arthur E. Schmidt
MAILING ADDRESS
ADDRESS AT WELL LOCATION Timothy Ave.

2. LOCATION NW ¼ SW ¼ Sec. 16 T. 19s N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) | 29-254-05 (Parcel No.) | Country PlaceII Unit 2 Blk. 30 Lot 18 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	25'	25'
calichie		25'	27'	2'
clay		27'	37'	10'
calichie		37'	40'	3'
clay		40'	50'	10'
calichie		50'	61'	11'
clay		61'	73'	12'
calichie		73'	83'	10'
clay gravel		83'	97'	14'
clay		97'	128'	31'
clay		128'	133'	5'
gravel	WB	133'	134'	1'
clay		134'	139'	5'
sand gravel	WB	139'	141'	2'
clay		141'	153'	12'
sand gravel	WB	153'	155'	2'
clay gravel		155'	169'	14'
clay		169'	170'	1'
sand gravel	WB	170'	172'	2'
clay		172'	183'	11'
sand gravel	WB	183'	186'	3'
clay gravel		186'	192'	6'
sand gravel	WB	192'	200'	8'

RECEIVED
JUL 10 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 6-17, 1991
Date completed 6-21, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼	Inches	0' Feet	140' Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation factory sawcut
Size perforation 1/8 x 3
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041

Nevada contractor's license number issued by the State Contractor's Board 30880

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dean
By driller performing actual drilling on site or contractor
Date 7-8-91

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627