

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15395

1. OWNER LENNY SEE / SECURITY PACIFIC BANK NV ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 11500 S. Center & Liberty Street
Reno, NV 89550 Reno, NV 89501
 2. LOCATION SE 1/4 SE 1/4 Sec 11 T 19N N/S R 19 E Washoe County
 PERMIT NO. M/O #330 SPW-2 001-191-05 Downtown Reno, NV
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE Monitoring X
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Tubex 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay, reddish brown, moderately plastic, organic matter		0	2	2
Gravelly sand, olive gray, poorly graded sand, subangular		2	15	13
Sandy gravel, poorly sorted, minor fines in matrix, volcanic clasts & cobbles	X	15	39	24
Gravelly sand, olive gray, poorly graded sand, subangular		39	45	6
Sandy gravel, poorly sorted, minor fines in matrix, volcanic clasts & cobbles		45	51	6

WELL DATA SUPPLIED BY GERAGHTY & MILLER, INC.
 (April 9, 1991)

Date started 12-13-90, 19____
 Date completed 12-14-90, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	5		

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

8. WELL CONSTRUCTION
 Diameter 9 5/16 inches Total depth 51 feet
 _____ inches
 _____ inches
 Casing record 51 ft. PVC Installed
 Weight per foot _____ Thickness sch 40

Diameter	From	To
<u>4</u> inches	<u>0</u> feet	<u>51</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Neat cement grout
 Depth of seal 2 foot Bentonite seal / 25 feet
 Gravel packed: Yes No
 Gravel packed from 27 feet to 51 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 0.020 screen
 From 31 feet to 51 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 39 feet below land surface
 Flow Not taken G.P.M. _____ P.S.I. _____
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number 22549 issued by the State Contractor's Board
 Nevada contractor's driller's number 908 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources 908 the on-site driller
 Signed Wayne Drilling, Inc.
By driller performing actual drilling on site or contractor
 Date April 10, 1991