WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35334
Permit No. 54969
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3684

1. OWNER Sally's Circle Homeowners Assoc.
MAILING ADDRESS 7108 Sixshooter Dr.
Las Vegas, NV 89119

ADDRESS AT WELL LOCATION —

2. LOCATION NW ¼ NE ¼ Sec. 23 T. 22 S R. 61 E. Clark County

PERMIT NO. 54969 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐ Quasi

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	20	20
Clay, some cobbles		20	40	20
Clay		40	80	40
Clay, some cobbles		80	120	40
Sand & gravel, cobbles		120	160	40
S & g, boulders		160	307	147
Clay		307	360	53

RECEIVED
MAR 07 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started November 12, 1990
Date completed November 15, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 360 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .188

Diameter	From	To
8 inches	+1 feet	357 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 360 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 2½ 8 rows
From 217 feet to 317 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 142 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 W. Harmon Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 856
Signed Richard Thompson (By driller performing actual drilling on site or contractor)
Date March 5, 1991

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627