

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35364
Permit No. 3328
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 3328

1. OWNER CITY OF LAS VEGAS
MAILING ADDRESS SPECIAL PROJECTS, 9th FLOOR
400 EAST STEUBENST AVE, LAS VEGAS, NV 89101

ADDRESS AT WELL LOCATION Mt Hood Street
4 LAS VEGAS BOULEVARD

2. LOCATION NN 1/4 DE 1/4 Sec 34 T. 19 N 8 R. 62 E CLARK County

PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well
 Replace
 Abandon
 Deepen
 Recondition
 Other _____
 Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Stock
 Test
 Cable
 Air
 Rotary
 RVC
 Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy silt</u>		<u>0'</u>	<u>65'</u>	<u>65'</u>
<u>Silty clay</u>		<u>65'</u>	<u>90'</u>	<u>25'</u>
<u>Clay</u>		<u>90'</u>	<u>110'</u>	<u>20'</u>
<u>Silty clay</u>		<u>110'</u>	<u>125'</u>	<u>15'</u>

8. WELL CONSTRUCTION

Depth Drilled	Feet	HOLE DIAMETER (BIT SIZE)	From	To	Feet	Feet
<u>125</u>		<u>4</u>	<u>0</u>	<u>125</u>	<u>125</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2'</u>			<u>0</u>	<u>125</u>

Perforations:
 Type perforation staked
 Size perforation 2 7/8 feet to 125 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete GROUT
 Bentonite
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 90 feet to 125 feet

9. WATER LEVEL
 Static water level 108 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DAN WILSON Contractor
 Address 4005 DIABLO AVE, LAS VEGAS
NEVADA 89103-5615

Nevada contractor's license number _____
 Issued by the State Contractor's Board _____
 Nevada driller's license number issued by the _____
 Division of Water Resources, the on-site driller M1589

Signed Dan Wilson
 By driller performing actual drilling on site or contractor _____
 Date _____

RECEIVED

JUN 11 1991
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started MAY 28, 1991
 Date completed MAY 28, 1991

7. WELL TEST DATA
 TEST METHOD: Bailor Pump Air Lift
 G.P.M. _____ Draw Down (Feet Below Static) _____ Time (Hours) _____