

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 8044

1. OWNER Ron Nailion (Nailion) ADDRESS AT WELL LOCATION Wilson Rd.  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 SE 1/4 Sec 13 T. 20s N/S R. 52 E Nye County  
 PERMIT NO. N/A 28-633-07 Charleston Park Ranchos Unit 1 Lot 4  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	27'	27'
calichie		27'	29'	2'
clay		29'	42'	13'
calichie		42'	44'	2'
clay		44'	52'	8'
calichie	WB	52'	55'	3'
clay		55'	68'	13'
calichie	WB	68'	71'	3'
clay		71'	89'	18'
calichie	WB	89'	91'	3'
clay		91'	117'	26'
caliche	WB	117'	120'	3'
clay		120'	137'	17'
calichie	WB	137'	140'	3'

8. WELL CONSTRUCTION  
 Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/2 Inches 0' Feet 140' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:  
 Type perforation factory sawcut  
 Size perforation 1/8 x 3

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 140' feet to 50' feet

9. WATER LEVEL  
 Static water level 47 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 7-5 1991  
 Date completed 7-10 1991

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor  
 Address HCR 78 Box 80358 Contractor  
Pahrump, Nv. 89041

Nevada contractor's license number 30880  
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1642  
 Division of Water Resources, the on-site driller.

Signed Thomas Dan  
 By driller performing actual drilling on site or contractor  
 Date 7-15-91

RECEIVED  
 JUL 17 1991  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV